



ROOF

208VAC, 3ø

CONDENSING UNIT

SEE SHEET E-811.

MECH EQUIPMENT ROOM

CONTROL WIRING

120VAC

AIR FLOW SW. (N.O.) (TYP.)

EF-1

EF-2

120VAC

208VAC, 3ø

MOTOR STARTER

IF-1

MOTOR OPERATED DAMPER FSD-3

N.C.

N.O.

120 VAC

A

SUPPLY AIR DUCT

AIR HANDLING UNIT A/C-1

SUPPLY AIR DUCT

208VAC, 3ø

T1

RADIO EQUIPMENT ROOM

120VAC

T2

N.O.

BATTERY ROOM

MOTOR OPERATED DAMPER FSD-2

N.C.

PLENUM

MOTOR OPERATED DAMPER FSD-1

N.C.

MECH EQUIPMENT ROOM

SEE DRAWING E-812 FOR TIE-INS TO FIRE ALARM SYSTEM